



City of Stockbridge Purchasing Division

City of Stockbridge City Hall
4640 North Henry Boulevard
Stockbridge, Ga 30281

ADDENDUM NO. 6

Solicitation No: Invitation To Bid (ITB) No. 2019-00016

Solicitation Title: Davis Road Sidewalks (CR 82/CS 755/Davis Rd@ 1 Loc) P.I.#0010731

ATTENTION ALL POTENTIAL BIDDERS:
MUST ADDENDUM. READ CAREFULLY AND FOLLOW ALL INSTRUCTIONS.

- ☒ This addendum forms a part of the contract documents, modifies the original bidding documents and shall be as binding as if contained therein.
- ☐ Return Addendum with Bid Submittal. Failure to do so may subject the Bidder to disqualification.
- ☐ Return Completed Revised Bid Pricing Sheets with Bid Submittal.

TO ALL PROSPECTIVE BIDDERS, PLEASE NOTE THE FOLLOWING CHANGES AND CLARIFICATIONS:

Words in ~~strikethrough~~ type are deletions from existing text. Words in **bold, underlined** type are additions to existing text.

1. The ITB Due Date has not changed. The ITB Due Date is 12:00 noon EDT p.m. on Wednesday July 24, 2019.

ADDITIONS / CLARIFICATIONS / CORRECTIONS

The following written question(s) and/or requests for clarification were received by the Contracts and Procurement Department prior to the deadline submission of questions and are hereby provided and answered below:



City of Stockbridge Purchasing Division

City of Stockbridge City Hall
4640 North Henry Boulevard
Stockbridge, Ga 30281

Question 1. Should the contractor provide design calculations signed by a registered professional engineer of the proposed modular block retaining wall?

Answer 1. Yes, the contractor shall provide Shop Drawings, including design calculations, from a registered professional engineer licensed in the state of Georgia. Please see subsection "1.04 Submittals" of specification section 630 - Segmental Concrete Retaining Wall System issued in Addendum No. 3.

Question 2. Will the city provide the length of the geogrid needed at each wall?

Answer 2. No, the geogrid design and calculations shall be included in the Shop Drawings submittal. Please see subsection "1.04 Submittals" of specification section 630 - Segmental Concrete Retaining Wall System issued in Addendum No. 3.

Question 3. This project has no cross sections to properly estimate the amount of fill especially in the areas without retaining walls. Please provide Cross sections.

Answer 3. Cross sections are not available.

Question 4. Although concrete is acceptable leveling pad material, gravel is a preferable material because for ease of workability and less expensive so would you consider gravel instead of concrete shown online Item #23, GDOT Item #630-0300.

Answer 4. Yes, subsection 2.01.C of specification section 630 issued in addendum #3 allows the use of concrete or aggregate.

Question 5. If a prime contractor is a certified GDOT DBE, will the self-perform work count to reach the DBE goal participation?

Answer 5. Yes.

Question 6. I noticed that the revised bid schedule indicates that there will be a concrete leveling pad, but the amended wall profile calls for a gravel leveling pad. Can you clarify which is correct?

Answer 6. "Drawing 31-01 issued in Addendum #3, Revise the legend in the bottom right corner of Drawing 31-01 to REPLACE the phrase "Gravel Leveling Pad" with the phrase "Leveling Pad". Please see subsection 2.01.C of specification section 630 issued in addendum #3 for additional information.



City of Stockbridge Purchasing Division

City of Stockbridge City Hall
4640 North Henry Boulevard
Stockbridge, Ga 30281

The City of Stockbridge's website and the State of Georgia Registry is the official location for the posting of all solicitation addenda and contract award results. It is the obligation of each Prospective Provider to frequently monitor the City's website in order to obtain complete and timely information. The City's website is located at <https://www.cityofstockbridge.com/default.aspx>

All other terms, conditions, and specifications of the solicitation remain unchanged.

Name of Company / Firm / Organization

Printed Name of Authorized Rep. / Title

Signature of Authorized Representative / Date